



**CAA/OT/MANDA/0034/2020-2021**

**10<sup>th</sup> November, 2020**

To: All Tenderers

**RE: SUPPLY AND INSTALLATION OF BATTERIES FOR THE SOLAR POWER AT MANDA AIRPORT.**

**TENDER NO: CAA/OT/MANDA/0034/2020-2021**

**ADDENDUM No.1**

The following are tender clarifications/addendum issued regarding the above tender in accordance to instructions to tenderers clause 2.6 of the bidding document for the referenced tender.

No	Question	Answer/Clarification
1.	We have noted that the tender is reserved for youth, women and PWD, however, AGPO certificate is not part of the required documents, does this mean anyone can participate?	This tender is reserved for the special group (Youth, Women and PWD).
2.	The following will form part of the evaluation criteria.	Attach a valid AGPO/YAGPO Certificate from National Treasury for enterprise registered under the preferences and reservation regulations 2013 - Registered Youth Group, Women Group or People Living with Disability Group Category.
3.	On the price schedule item No.1, the tender requires the removal of 48 no. 2V 2000AH batteries, including transportation and storage as directed by the procuring entity', For purposes of accurate pricing, kindly provide the proposed storage location.	The storage location is within the site, approximately less than 20m away. Vehicle transportation not required.
4.	On the price schedule item no.3, the tender requires supply of 25m of 25mm <sup>2</sup>	25m is the total length for both positive(+ve) and negative (-ve) cables.

	solar cables. We seek to know whether the 25m is the total length for both the positive and negative cables (+ve 12.5m and -ve 12.5m) or each is 25m coming to a total of 50m.	
5.	For us to determine the refrigerant pipe length, we would like to know the average distance between the indoor and outdoor unit.	The air-conditioning mounting distance is back to back where Maximum pipe length will be 5m gas line and 5m Liquid line. Refrigerant R410A.
6.	Item seven of the price schedule requires supply and fitting of glass to the main door, kindly advise the preferred thickness of the glass.	Glass preferred should be laminated 6mm thickness with tint.
7.	Is a site visit a mandatory requirement?	No. It is not a mandatory requirement.

The closing/opening date is hereby extended to **17<sup>th</sup> November, 2020** from **11<sup>th</sup> November, 2020 at 11.00 a.m.**

Kindly amend your tender accordingly and ensure the tender is valid for **120** days from the **NEW** closing/opening date of **17<sup>th</sup> November, 2020 at 11.00 am.**

This addendum forms part of the bidding document and is binding on all bidders. All other conditions remain the same.

  
**Patrick K. Wanjuki**  
**GM (PROCUREMENT AND LOGISTICS)**  
**For: MANAGING DIRECTOR/CEO**