



**Kenya Airports Authority**

Head Office, Airport North Road  
 P.O. Box 19001 - 00501 Nairobi, Kenya  
 Tel: +254 - 020 - 822111 / 6611000 / 6612000  
 Fax: +254 - 020 - 822078, 827304  
 Email: info@kaa.go.ke  
 www.kaa.go.ke

**KAA/OT/KIA/0074/2020-2021**

**8<sup>th</sup> March, 2021**

**To: All Tenderers**

**RE: TENDER FOR REPLACEMENT OF BATTERIES FOR UNINTERRUPTIBLE POWER SUPPLY (UPS) SYSTEMS AT KISUMU INTERNATIONAL AIRPORT.**

**TENDER NO: KAA/OT/KIA/0074/2020-2021**

**ADDENDUM NO.2**

The following are tender clarifications/addendum issued regarding the above tender in accordance to instructions to tenderers clause 2.6 of the bidding document for the referenced tender.

NO.	Query	Response
1.	Section 4 of page 41 requires "Supply and install 12V/100AH @20HR batteries for APC Galaxy 500 60kVA UPS as per the specification" yet existing batteries are 60AH and perfectly fitting in the cabinet making the cabinets smaller to fit and house the proposed 12V/100AH	Allow for extension of the existing cabinets to accommodate the <b>100AH</b> batteries on bill of quantities <b>section 6 page 41</b> Unit- Item, <b>Quantity - 2</b>

The closing/opening date and time remains to be **11<sup>th</sup> March, 2021 at 11:00 am** as per addendum No.1 at the same time and place as per the Tender Document.

Kindly amend your tender accordingly and ensure the tender is valid for 120 days and the tender security/Bid bond is valid for 150 days from the new closing/opening date and time on **11<sup>th</sup> March, 2021 at 11:00 a.m.**

This addendum forms part of the bidding document and is binding on all bidders. All other conditions remain the same.

**Patrick K. Wanjuki**  
**GENERAL MANAGER**  
**PROCUREMENT AND LOGISTICS**  
**For: MANAGING DIRECTOR/CEO.**