



**KAA/OT/ES/JKIA/0108/2020-2021**

**15<sup>th</sup> July, 2021**

To: All Tenderers

**RE: SUPPLY AND INSTALLATION OF 11KV CABLE SERVING SUBSTATION  
IB AT JOMO KENYATTA INTERNATIONAL AIRPORT.**

**TENDER NO: KAA/OT/ES/JKIA/0108/2020-2022**

**ADDENDUM No.2**

The following are tender clarifications/addendum issued regarding the above tender in accordance to instructions to tenderers clause 10 of the bidding document for the referenced tender.

ITEM	BIDDERS QUERRIES	CLARIFICATION
1	Whether cable cores are Copper or Aluminium ?	<ul style="list-style-type: none"><li>The cable core is copper.</li></ul>
2.	Hatari slabs are inserted in Scope of Work but NOT in BQ, kindly advise.	<ul style="list-style-type: none"><li>Yes they are not in the BQ but need to be quoted for. The supply and installation of the cable is as captured in the scope of works. "HATARI TILES/ SLABS" are required for the distance of cable installation length.</li></ul>

The closing/opening date remains on **20<sup>th</sup> July, 2021 at 11.00 a.m.**

Kindly ensure the tender is valid for **126** days and the tender surety is valid for **156** days from the closing/opening date of **20<sup>th</sup> July, 2021 at 11.00 am.**

This addendum forms part of the bidding document and is binding on all bidders. All other conditions remain the same.

**Patrick K. Wanjuki**  
**GM (PROCUREMENT AND LOGISTICS)**  
**For: MANAGING DIRECTOR/CEO**