



CAA/OT/ES/JKIA/0108/2020-2021

23rd July, 2021

To: All Tenderers

**RE: SUPPLY AND INSTALLATION OF 11KV CABLE SERVING
SUBSTATION IB ATJOMO KENYATTA INTERNATIONAL
AIRPORT**

TENDER NO: CAA/OT/ES/JKIA/0108/2020-2021

ADDENDUM No.5

The following are tender clarifications/addendum issued regarding the above tender in accordance to instructions to tenderers clause 10 of the bidding document for the referenced tender.

Item	REQUEST INFORMATION	CLARIFICATION
1	Page 68. The specifications and Priced Activity schedule, item S/No. 3 states "Carry out excavation & back filling to 2m deep of the cable trench". We submit that whereas rock is a common feature at the surroundings and is likely to be there at the site, there is no indication how excavated rock shall be measured and paid for, noting that rock excavation requires substantially more resources and treatment than excavation on normal soil. Kindly clarify.	The existing route is within the existing cable route and we don't anticipate rock to that extent
2	Clarify whether there shall be excavation across pavements, across roads and across drainage structures who shall be responsible for their reinstatement and how such activities shall be paid for	The wayleave area has no structures

3	Clarify if there are existing services, which are they, who shall be responsible for such services and how such activities shall be paid.	The route has ONLY High Voltage 66KV line which shall remain undisturbed by the contractor
4	As you may be aware, the KAA website was not working for a while. The failure of the KAA website made it impossible to access the tender details and bidding documents for long, hence delaying the possibility to prepare bids. Note that the cable required in the tender is not manufactured locally and therefore must involve our international manufacturer. As a consequence, we seek extension of bid submission deadline by one week	Extension of time has been granted to 29 th July 2021
5	Item No. 6 of the Technical Evaluation criteria (Qualification of site foreman) (4) States as follows Registered with EPRA class A1 on electrical installation.	It is hereby amended to state as follows; Diploma Electrical technician, or approved equivalent registered with EPRA class B on electrical installation with minimum 5 years' experience in Medium Voltage installation and proof of certification in Medium Voltage Cables jointing and installation.
6	Item No.1 of the Technical Evaluation criteria states that "Tenderer shall demonstrate participation as contractor, management contractor or subcontractor, in at least three (3) electrical Medium voltage electrical installations and cable terminations contracts within the above mentioned years, with an AVERAGE value of at least Kenya Shillings fifteen million [Kshs.15,000,000], that have been successfully or substantially completed(proof shall be in form of completion certificates or partial completion certificate whose works must be 70% substantially completed, claim Invoices with details of the clients address, contact person telephone and email Must be provided). <ul style="list-style-type: none">• Copy of Defects Liability	This criterion has been amended as follows; Tenderer and at least one party in a Joint Venture shall demonstrate participation as contractor, management contractor or subcontractor, in at least three (3) electrical Medium voltage electrical installations and cable terminations contracts within the last three years (2017, 2018 and 2019), with an AVERAGE value of at least Kenya Shillings five million [Kshs. 5,000,000] , that have been successfully or substantially completed(proof shall be in form of completion certificates or partial completion certificate whose works must be 70% substantially completed, claim Invoices with details of the clients address, contact person telephone and email Must be provided).

	<ul style="list-style-type: none">• Certificates; or Copy of completion certificate; or• Interim payment certificate of not less than 70% value of the contract;	
--	---	--

The closing/opening date remains on **29th July, 2021** at **11.00 a.m.**

Kindly ensure the tender is valid for **126** days and the tender surety is valid for **156** days from the closing/opening date of **29th July, 2021** at **11.00 am.**

This addendum forms part of the bidding document and is binding on all bidders. All other conditions remain the same.



Patrick K. Wanjuki
GM (PROCUREMENT AND LOGISTICS)
For: MANAGING DIRECTOR/CEO