



KAA/OT/MANDA/0073/2021-2022

21st October, 2021

To: All Tenderers

RE: **SUPPLY OF BATTERIES AND RELATED SERVICES FOR THE SOLAR POWER PLANT AT MANDA AIRSTRIP, LAMU**

TENDER NO: KAA/OT/MANDA/0073/2021-2022

CLARIFICATION NO.1

The following are tender clarifications/addendum issued regarding the above tender in accordance to instructions to tenderers clause 7 of the bidding document for the referenced tender.

No.	Question	Answer/ Clarification
1.	Is there a reason why you prefer lead-acid batteries over lithium-ion batteries?	Yes. Lithium Ion Phosphate batteries or their approved equivalent are the best in terms of performance and durability. However, the Lithium Ion Phosphate batteries require to be installed in a temperature controlled environment throughout their life. Without technical personnel at the station, it would be a risk to engage in such an investment. The requirement is Lead- acid batteries.

The closing/opening date remains on **28th October, 2021 at 11.00 a.m.**

Kindly amend your tender accordingly and ensure the tender is valid for **126** days from the closing/opening date of **28th October, 2021 at 11.00 am.**

All other requirements in the bidding document and addendums issued shall remain the same.

This addendum forms part of the bidding document and is binding on all bidders. All other conditions remain the same.



Patrick K. Wanjuki
GENERAL MANAGER
PROCUREMENT AND LOGISTICS
For: MANAGING DIRECTOR/CEO