



**CAA/OT/EIA/1509/2018-2019**

**28<sup>th</sup> May, 2019**

To: Tenderers

Dear Sir/Madam,

**RE: SUPPLY & INSTALLATION OF HIGH MAST LED FLOODLIGHTS AT  
ELDORET INTERNATIONAL AIRPORT  
TENDER NO. CAA/OT/EIA/1509/2018-2019**

**ADDENDUM NO. 1**

The following are tender clarifications/addendum issued regarding the above tender in accordance to instructions to tenderers clause no. 7 of the bidding document.

NO	ADDITIONAL CLARIFICATIONS/ BIDDERS' QUESTIONS	REFERENCE PAGE	RESPONSE
I.	The actual scope of the tender is not clear on the tender document, kindly advise how many nos. of 30m high mast to be installed.	Pages 40 - 45	<p><b>Amend the following sections of Technical Specifications as below:</b></p> <p><b>Scope</b> <b>Amend to read as follows:</b> The contractor shall supply, deliver and install and test LED Floodlight fittings. The contractor shall supply and install reliable and high performance LED Floodlight fittings. The Fittings shall be engineered to deliver significant energy saving, an ideal solution for diverse floodlighting applications.</p> <p>The product shall be designed to meet relevant performance and safety standards, offering reliable and long lasting performance.</p> <p><b>General</b> <b>Amend to read as follows:</b> This specification contains the minimum requirements for the design, manufacture and testing of LED Floodlight fittings. The LED Floodlight fittings shall deliver significant energy saving, an ideal solution for diverse floodlighting applications. The product also shall be designed to relevant performance and safety</p>

			standards, offering reliable and long lasting performance. <b>Note: There are no Masts to be installed in this tender</b>
2.	A bidder wanted to know the number of 400W and 200W LED Lighting fittings to be installed and their distribution.	Page 49	Bidders are required to replace the <b>existing lighting fittings</b> but the existing masts shall remain. The following are the required quantities of LED floodlight fittings to be installed: i. <b>400W – 35No.</b> distributed as follows: - 4 poles – 6 fittings - 2 Poles – 4 fittings - 1 Pole – 3 fittings ii. <b>200W – 20No.</b> distributed on 5 poles with 4 fittings each
3.	A bidder has requested for drawings and photos of samples of LED Floodlight fittings to be installed in this tender.	<b>Pages 40 - 45</b>	The Technical specifications given in the tender document are adequate. The bidder is to supply and install <b>aviation type</b> of LED floodlight fittings matching those specifications.  The new LED Floodlight fittings shall be used to replace (retrofit) the existing conventional lighting fittings.

The closing/opening date is hereby extended to **7<sup>th</sup> June, 2019** from 29<sup>th</sup> May, 2019

Kindly amend your tender accordingly and ensure the tender is valid for **120 days** and the tender surety valid for **150 days** from the **NEW** closing/opening date on **7<sup>th</sup> June, 2019** at **11.00 a.m.** Venue remain the same.

This addendum forms part of the bidding document and is binding on all bidders. All other relevant conditions remain the same.

**Patrick K. Wanjuki**  
**GM PROCUREMENT AND LOGISTICS**  
**For: MANAGING DIRECTOR/CEO**