



CAA/OT/ JKIA/0008/2019 - 2020

5th August, 2019

To: All Tenderers

RE: SUPPLY AND REPLACEMENT OF TAXIWAY LIGHTING FITTINGS AND DAMAGED SIGNAGE AT JOMO KENYATTA INTERNATIONAL AIRPORT

**TENDER NO CAA/OT/ JKIA/0008/2019 - 2020
ADDENDUM NO.1**

The following are tender clarifications/addendum issued regarding the above tender in accordance to instructions to tenderers clause no. 7.1 and 7.2 of the bidding document

NO	QUERY	RESPONSE
1	<p>We write in connection with the above named tender.</p> <p>I. The Preamble to General Conditions, Clause 1.6 on Costs, Overhead Charges and Profit, states as follows; The percentage to cover profit entitlement, where applicable, is _____ (insert). We request that you provide missing information.</p>	<p>Bidders to insert the percentage of profit and overhead cost applicable to PC items. The % Profit and overhead cost MUST be put on the summary PAGE of the Total Bid Price.</p>
2	<p>The scope of works in Section V: Technical Specifications; Clause 1.1. (II) Work includes - Supply and install 5-step 10kva 415vac constant current regulators as per specifications. The requirement is amplified in Section VII: Bills of Quantities; Clause 2.2.13 which requires that we quote for Supply and install 5-step 10kVA 415Vac constant current regulators as per specification - 2 No.</p> <ul style="list-style-type: none"> We request that provide specifications for constant current regulators 	<p>Compliance Standards</p> <ul style="list-style-type: none"> -ICAO -Aerodrome Design Manual, Part 5 -Electrical Systems Para 3.2.14 to 3.2.16 -UK CAP 168 -FAA AC/5345-10F -IEC 61822 -EN 50081-2 : 1993 -EN 6000-6-2 : 1999 <p>Output power ratings</p> <p>415V: Outputs 10kVA</p> <p>Power factor</p> <p>At nominal resistive load, nominal output current and nominal input voltage:- Up to 0.9 for ratings up to 10 KVA</p>

		<p>Efficiency At nominal power into resistive load, maximum brilliancy and Nominal input voltage:- 90% or better</p> <p>Output current ratings 6.6A</p> <p>Input voltage ratings 415 2 Phase, 50 Hz</p> <p>Control Voltage 24VDC</p> <p>Output Ports Serial I/O board (SIO) IRMS interface. SCC/V3 Module for Single Lamp Control.</p> <p>Temperature Range Without monitoring circuitry: -40 to +55 °C (-40 to +131 °F) With monitoring circuitry: 0 to +55 °C (-18 to +131 °F)</p> <p>Relative Humidity 0 to 100% (noncondensing)</p> <p>Altitude Sea level to 6,600 ft (2000 m)</p>
3.	Request for another Site Visit/Pre-Bid Meeting	This has been granted. It will take place on 7 th August 2019 at 11:00am at the Conference Room located at the roof top of the Parking Garage in JKIA.

The closing/opening date is hereby extended to **21st August, 2019** from **13th August, 2019**.

Kindly amend your tender accordingly and ensure the tender is valid for **120 days** and the tender surety is valid for **150 days** from the **NEW** closing/opening date of **21st August 2019** at **11.00 am**.

This addendum forms part of the bidding document and is binding on all bidders. All other conditions remain the same.

Patrick K. Wanjuki
GM (PROCUREMENT AND LOGISTICS)
For: MANAGING DIRECTOR/CEO