



CAA/OT/ JKIA/0008/2019 - 2020

6th August, 2019

To: All Tenderers

RE: SUPPLY AND REPLACEMENT OF TAXIWAY LIGHTING FITTINGS AND DAMAGED SIGNAGE AT JOMO KENYATTA INTERNATIONAL AIRPORT

**TENDER NO. CAA/OT/ JKIA/0008/2019 - 2020
ADDENDUM NO.2**

The following are tender clarifications/addendum issued regarding the above tender in accordance to instructions to tenderers clause no. 7.1 and 7.2 of the bidding document

NO	QUERY	RESPONSE
1	10.3 Contingency 10% unless specified add in subtotal. There is no provision on the BQ for this is this mandatory.	Allow for 5% contingency amount on the subtotal on summary page of BOQ which will form part of Bid Price.
2	Page 50 2.3 Quality assurance submittal A/B after award Or in tender submitted.	Quality Assurance Documentation SHALL be submitted by the successful bidder.
3	Page 7 2.3A Similar nature of works This could be any joint venture partner or there is option to provide other electrical works done as KAA is the only user of Taxi way lighting in the whole country this narrows down to selected Bidders..	Past experience is on Electrical Installation works with component of cabling and ducting.
	Page 51 Average LED life of 100,000 hours under high-intensity conditions and more than 180,000 hours under typical operating conditions.	This is a technical specification requirement.

The addendum forms part of the bidding document and is binding on all bidders. All other conditions remain the same.

Patrick K. Wanjuki
GM (PROCUREMENT AND LOGISTICS)
For: MANAGING DIRECTOR/CEO