



20th May, 2020

To: All Tenderers

RE: REPLACEMENT OF AGL CABLES AND ACCESSORIES AT
ELDORET INTERNATIONAL AIRPORT.

TENDER NO. KAA/OT/EIA/0089/2019-2020

ADDENDUM NO. 5

The following are tender clarifications/addendum issued regarding the above tender in accordance to instructions to tenderers clause 7.1 of the bidding document for the referenced tender:-

ITEM NO.	ADDITIONAL CLARIFICATIONS / BIDDERS' QUESTIONS	REF. PAGE	RESPONSE
1.	According to the CCR's specs a module for single lamp monitoring should be included. Do you require the ILCMS (individual light control & monitoring system). In this case what about the remote units?	Addendum II	This tender does not require the ILCMS remote units. Only CCRs are required to have the module for interfacing with remote individual light monitoring system.
2.	In the tender you require availability of Electrical Technician holding a Diploma in Electrical Engineering. A qualification in Electrical Engineering Technician Part II that was offered by some government Technical Institutions in Kenya was considered equivalent to a Diploma in the technical field concerned. We hereby request that you clarify that a qualification in Electrical Engineering Technician Part II shall be considered.	Page 28	The requirements for this tender is a Technician holding a diploma in Electrical Engineering. For any contrary qualification, the bidder has to provide proof from Kenya National Examination Council.
3.	In the BOQ Schedule I- Preliminaries item 1.8 requires tenderers to provide for hiring a vehicle with a driver for exclusive use by the project team whose minimum specifications are: 4WD	Page 58 (Item 1.8)	Our response is as follows: a) Both Diesel and petrol propelled Double Cab


	<p>Double Cabin Pick-Up, Minimum Engine Capacity: 2400cc Petrol, with mileage less than 10,000km.</p> <p>a) The bidder wanted to know if Diesel propelled Double Cabin Pick-up is would be acceptable since they are more common in Kenyan Market.</p> <p>b) The bidder also raised the issue of age of Double Cabin Pick-up to be provided arguing that the 10,000km is a relatively new vehicle.</p>		<p>Pickups will be acceptable.</p> <p>b) The age of the Vehicle to be provided in this tender shall remain as 10,000km or less as per tender specifications.</p>
4.	<p>BOQ item 4.2 – Duct Crossings – installation of Ducts/ Pipes encased in concrete for cable crossings on Roads and Taxiways (installation of Concrete works only); we request that you include a BOQ item with required quantity of concrete to enable pricing in order to achieve equal treatment among all tenderers. and</p>	Page 66	<p>The estimated quantity of Concrete required is: Item 4.2(i): 100CM Item 4.2(ii): 35CM</p> <p>Note this is a provisional item and actual quantities shall be determined once the actual excavations are done and as per Civil Engineer's advice.</p>
5.	<p>In BoQ item 4.3. – Excavation for Duct Crossing, Backfilling and compaction in accordance with the specifications for Taxiways and Roads; we request that you include a BOQ item with required quantity of asphalt to enable pricing in order to achieve equal treatment among all tenderers.</p>	Page 66 (Item 4.3.1)	<p>Add Item 4.3.1 (d) Cutting and Reinstatement of Taxiway surface with Asphalt: Total Volume of Asphalt is 50CM</p> <p>Add Item 4.3.1 (e) Cutting and Reinstatement of Road surface with Asphalt: Total Volume of Asphalt is 7.5CM</p> <p>Note that these are provisional quantities and the actual quantities will be determined after excavations are done and as per Civil Engineers advice.</p>
6.	<p>BOQ Item 4.4 Drawing for manholes.</p>	Page 67 Item 4.4	<p>Drawings provided in Addendum no. 2 which</p>

			gives the dimensions of the manholes. The quantities are also provided in the BOQ.
--	--	--	--

The closing/opening date has been extended to **28th May, 2020** from **21st May, 2020**.

Kindly amend your tender accordingly and ensure the tender is valid for **120 days** and the tender surety valid for **150 days** from this closing/opening date on **28th May, 2020** at **11.00 am**.

This addendum forms part of the bidding document and is binding on all bidders. All other conditions remain the same.



Patrick K. Wanjuki
GENERAL MANAGER PROCUREMENT AND LOGISTICS
For: MANAGING DIRECTOR/CEO

